



2018 Property Maintenance/Housing Inspector Question Of The Week

Where the fire department connection is not visible to approaching fire apparatus, the fire department connection shall be indicated by an approved sign mounted on the street front or on the side of the building with the letters "FDC" not less than __ inches high and words in letters not less than __ inches high or an arrow to indicate the location.

- A) 6,2
- B) 8,3
- C) 3,3
- D) 4,4

[F] 704.5 Fire department connection. Where the fire department connection is not visible to approaching fire apparatus, the fire department connection shall be indicated by an *approved* sign mounted on the street front or on the side of the building. Such sign shall have the letters "FDC" not less than 6 inches (152 mm) high and words in letters not less than 2 inches (51 mm) high or an arrow to indicate the location. Such signs shall be subject to the approval of the fire code official.

