



2018 CBO Building Codes & Standards Question Of The Week

A minimum of ___ percent of all recreational vehicle sites with electrical supply shall each be equipped with a 30-ampere, 125-volt receptacle.

- A) 25
- B) 50
- C) 70
- D) 85



Part VI. Recreational Vehicle Parks

551.71 Type Receptacles Provided.

(A) 20-Ampere. Every recreational vehicle site with electrical supply shall be equipped with recreational vehicle site supply equipment with at least one 20-ampere, 125-volt receptacle.

(B) 30-Ampere. A minimum of 70 percent of all recreational vehicle sites with electrical supply shall each be equipped with a 30-ampere, 125-volt receptacle conforming to **Figure 551.46(C)(1)**. This supply shall be permitted to include additional receptacle configurations conforming to **551.81**. The remainder of all recreational vehicle sites with electrical supply shall be equipped with one or more of the receptacle configurations conforming to **551.81**.




FIGURE 551.46(C)(1) Configurations for Grounding-Type Receptacles and Attachment Plug Caps Used for Recreational Vehicle Supply Cords and Recreational Vehicle Lots.